



Temporary Electric Power – WELL Sheet

WELL Sheet #: 1014
Revision: 2021/11

Date:		Job:		:		
Observation team member:				Signature:		
Observation team member:				Signature:		
Observation team member:				Signature:		
Location of Work:				Yes	No	N/A
1.	GFCI controlled outlets and panels are labeled (traceable to panel/breaker) and tested.					
2.	Electrical cords are inspected and free of breaks in the insulation and approved for the type of usage.					
3.	Outlets, receptacles, junction boxes, etc., are approved installations and maintained as required.					
4.	Non-conductive material is used where electrical cords are suspended or secured.					
5.	Temporary lighting is installed as required (50 lux minimum) using approved materials. Light bulbs and fluorescent tubes are guarded as required.					
6.	Temporary electrical outlets, receptacles, junction boxes, and panels are electrically grounded.					
7.	Buried temporary electrical cables are marked on the surface to avoid accidental contact from excavating.					
	NOTE: Consult with Total Health & Safety (Safety Specialist) and/or other SME(s) as necessary to verify these criteria.					
Comments:						